



CARRIER PIPE NOMINAL DIA.	CASING PIPE		MINIMUM RUNNER SIZE
	MIN. O.D.	MIN. WALL THICK	
4"	12"	0.188"	2" x 4"
6"	16"	0.250"	2" x 4"
8"	18"	0.282"	2" x 4"
12"	22"	0.344"	2" x 4"
16"	28"	0.406"	2" x 6"
20"	32"	0.469"	2" x 6"

- NOTES:
- 1.) NEOPRENE OR PVC RUNNERS MAY BE USED AS AN ALTERNATIVE TO TREATED REDWOOD.
 - 2.) TRENCH LAID CASINGS SHALL BE DESIGNED AND INSTALLED TO CONDUIT STANDARDS.



STANDARDS &
SPECIFICATIONS

REVISED:

**BORE CASING
DETAIL**

DATE:

DRAWING NO. 200-08